

## What are Drinking Water Standards?

The sources of drinking water, both tap water and bottled water include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include: (A) Microbial contaminants such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife; (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming; (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm runoff and septic systems; (E) Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production or mining activities.

In order to ensure that tap water is safe to drink, USEPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Federal Environmental Protection Agency's Safe Drinking Water Hotline at (1-800-426-4791).

### Drinking Water Notice-Avon Lake Regional Water Department:

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the weeks of 11/13/22—11/26/22 and 11/27/22—12/3/22 we did not monitor for Cyanobacteria Screening and therefore cannot be sure of the quality of our drinking water during that time. What should I do? This notice is to inform you that Avon Lake public water system did not monitor, and report results for the presence of Cyanobacteria Screening in the public drinking water system during the weeks of 11/13/22—11/26/22 and 11/27/22—12/3/2022 monitoring period, as required by the Ohio EPA. You do not need to take any action in response to this notice. What is being done? Upon being notified of this violation, the water supply was required to have the drinking water analyzed for total Cyanobacteria Screening according to their current monitoring schedule. The water supplier will take steps to ensure that adequate monitoring will be performed in the future. A sample will be collected on 6/2/23 and sample results or additional information may be obtained by contacting Avon Lake at: Avon Lake Water System, (440)933-6226, 201 Miller Road, Avon Lake, OH 44012 PWSID: OH4700311 Facility ID: 4755816


# DRINKING WATER CONSUMER CONFIDENCE REPORT REPORTING YEAR 2022

PRESENTED BY SHEFFIELD VILLAGE  
WATER SYSTEM and Village Administrator:

Ken Kaczay

440-949-6210

PWS ID# OH4701203



In 2022 Sheffield Village PWS had a current, unconditioned license to operate our water system from the Ohio EPA

The Sheffield Village Water System has prepared the following report to provide information to you, the consumer, on the quality of our drinking water. Included within this report is general health information, water quality test results, how to participate in decisions concerning your drinking water and water system contacts.

### Where does my water come from?

The Village of Sheffield receives its drinking water from the Avon Lake Municipal Utilities Department. The Avon Lake Water treatment facility draws its water from Lake Erie.

For the purposes of source water assessments, all surface waters are considered to be susceptible to contamination. By their nature surface waters are accessible and can be readily contaminated by chemicals and pathogens with relatively short travel times from source to the intake. Based on the information compiled for this assessment, the Avon Lake Water System drinking water source protection area (CAZ) is susceptible to contamination from municipal waste water treatment discharges, industrial waste water discharges, air contamination deposition, combined sewer overflows, runoff from residential, agricultural and urban areas, oil and gas production and transportation, and accidental releases and spills from rail and vehicular traffic as well as from commercial shipping operations and recreational boating.

It is important to note that this assessment is based on available data, and therefore may not reflect current conditions in all cases. Water quality, land uses and other activities that are potential sources of contamination may change with time. While the source water for the City of Avon Lake is considered susceptible to contamination, historically, the Avon Lake Public Water System has effectively treated this source water to meet drinking water quality standards. If you would like to request a copy of Avon Lake Water Department's consumer confidence report, please contact Jason Gibboney at 440-933-3229.

### Drinking Water Notice-Sheffield Village Water Department:

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the 2022 Annual time period we did not monitor for disinfection by-products and therefore cannot be sure of the quality of our drinking water during that time. What should I do? This notice is to inform you that Sheffield Village PWS did not monitor and report results for the presence of Disinfection By-Products in the public water system during the 2022 Annual time period, as required by the Ohio EPA. You do not need to take action in response to this notice. What is being done? Upon being notified of this violation, the water supply was required to have the drinking water analyzed for Disinfection By-Products according to their current monitoring schedule. A sample was collected on 11/21/2022 which came back negative. The water supplier will take steps to ensure that adequate monitoring will be performed in the future. Sample results and additional information may be obtained by contacting Sheffield Village PWS at: Kenneth Kaczay, Village Administrator, (440)949-6210, 4480 Colorado Ave., Sheffield Village, OH 44054. PSWID: OH4701203 Facility ID: DS1

## Microbiological Contaminants

Total coliform, Fecal coliform, and E-coli are naturally present in the environment. Sheffield Village Water Dept. personnel collect samples throughout our system routinely testing for the presence of these contaminants. Through proper disinfecting practices we have not found this in our finished water supply.

### Who needs to take Special Precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infection. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

### How Can You Learn More?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Federal Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). To participate, or for more information, contact our community's water system department at (440)949-6210.

### Lead and Drinking Water

The Village of Sheffield has been in full compliance with all regulations for lead and copper control. If present, elevated levels of lead can cause serious health problems, especially for pregnant and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Sheffield Village is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 800-426-4791 or at <http://www.epa.gov/safewater/lead>.

### What is the Latest Information on Disinfection?

Disinfection is an absolute essential component in the treatment of drinking water. Trihalomethanes (TTHM's) and Haloacetic Acids (HAA's) are by-products of chlorinating water containing organic matter. There are some health concerns related to higher levels of disinfection byproducts. The EPA lowered the MCL for the THM's in 2002 and added a MCL for HAA's due to these health issues. Avon Lake also monitors the total organic carbon before and after sedimentation to minimize the organic matter in the water prior to adding chlorine.

Contaminants (Units)	MCLG	MCL	Level Found	Range of Detections	Violation	Sample Year	Typical Source of Contaminants
<b>Microbiological Contaminants (Tested by wholesaler at their entrypoint-Avon Lake Regional Water)</b>							
Turbidity (NTU) <sup>1</sup>	NA	TT	0.16	0.02 to 0.16	No	2022	Soil Runoff
Turbidity (% samples meeting standard)	NA	TT	100%	100%	No	2022	Soil Runoff
Total Organic Carbon (TOC) <sup>2</sup>	NA	TT	1.24	1.00 to 1.6	No	2022	Naturally present in the environment
<b>Disinfectants and Disinfection Byproducts<sup>3</sup></b>							
Total Chlorine (ppm)	MRDLG = 4	MRDL = 4	1.22	1.04 to 1.42	No	2022	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb) <sup>4</sup>	NA	60	12.0	9.7 to 12.0	No	2022	By-product of drinking water disinfection
Total Trihalomethanes (TTHM) (ppb) <sup>4</sup>	NA	80	34.9	26.9 to 34.9	No	2022	By-product of drinking water disinfection
<b>Inorganic Contaminants (Tested by wholesaler at their entrypoint-Avon Lake Regional Water)</b>							
Barium (ppm)	2	2	0.02	NA	No	2022	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	0.75	0.75 to 1.24	No	2022	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate (ppm)	10	10	0.92	<0.1 to 0.92	No	2022	Run off from fertilizer use, Leaching from septic tanks, Sewage; Erosion of natural deposits
<b>Lead and Copper</b>							
	Action Level (AL)	Individual Results over the AL	90% of test levels were less than	Violation	Year Sampled	Typical source of Contaminants	
Lead (ppb)	15 ppb	NA	<3.0 ppb	No	2022	Corrosion of household plumbing systems; erosion of natural deposits	
	<b>Zero out of 20 samples were found to have lead levels in excess of the lead action level of 15 ppb.</b>						
Copper (ppm)	1.3 ppm	NA	.053 ppm	No	2022	Erosions of natural deposits; leaching from wood preservatives; Corrosions of household plumbing systems	
	<b>Zero out of 20 samples were found to have copper levels in excess of the copper action level of 1.3 ppm.</b>						

<sup>1</sup>Turbidity is a measure of the cloudiness of water and is an indication of the effectiveness of our filtration system. The turbidity limit set by the EPA is 0.3 NTU in 95% of the samples analyzed each month and shall not exceed 1 NTU at any time. As reported in the chart the Sheffield Village Water Department's highest recorded turbidity result for 2022 was 0.16NTU and lowest monthly percentage of samples meeting the turbidity limits was 100%.

<sup>2</sup>The value reported under "Level Found" for Total Organic Carbon (TOC) is the lowest ratio between percentage of TOC actually removed to the percentage of TOC required to be removed. This removal ratio is calculated as the ratio between the actual TOC removal and the TOC rule removal requirements and other parameters. A value of at least one (1) indicates that the water system is in compliance with TOC removal requirements.

<sup>3</sup>These contaminants level found is the highest compliance value based on a running annual average. This average includes results from 2021 & 2022.

<sup>4</sup> Disinfection byproducts are the result of providing continuous disinfection of your drinking water and form when disinfectants combine with organic matter naturally occurring in the source water. Disinfection byproducts are grouped into two categories. Total Trihalomethanes (TTHM) and Haloacetic Acids (HAA5). USEPA sets standards for controlling the levels of disinfectants and disinfectant byproducts in drinking water, including both TTHMs and HAA5s."

**Definitions**

1. Action Level (AL)- The concentration of a contaminant which, if exceeded, triggers treatment or other re-quirements which a water system must follow.
2. Contaminant-Any physical, chemical, biological, or radiological substance or matter in water.
3. Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
4. Maximum Contaminant Level Goal (MCLG) -The level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
5. Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
6. Maximum Residual Disinfectant Level Goal (MRDLG) - The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
7. ND - Not Detected
8. NA - Not Applicable
9. NTU - Nephelometric Turbidity Units
10. Parts per billion (ppb) or Micrograms per Liter (ug/L) are units of measure for concentration of a contaminant. A part per billion corresponds to one second in 31.7 years.
11. Parts per million (ppm) or Milligrams per liter (mg/L) are units of measure for concentration of a contaminant. A part per million corresponds to one second in a little over 11.5 days.
12. PFAS: Per-and polyfluoroalkyl substances (PFAS) are a group of man-made chemicals applied to many industrial, commercial and consumer products to make them waterproof, stain resistant, or nonstick. PFAS are also used in products like cosmetics, fast food packaging, and a type of firefighting foam called aqueous film forming foam (AFFF) which are used mainly on large spills of flammable liquids, such as jet fuel. PFAS are classified as contaminants of emerging concern, meaning that research into the harm they may cause to human health is still ongoing.
- 13.Total Organic Carbon (TOC) has no health effects. However, TOC provides a medium when the water is disinfected for the formation of disinfection byproducts. TOC removal early in the treatment plant is required.
- 14.Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water. For example Avon Lake Regional Water adds orthophosphate to maintain compliance with the lead and copper rule.
15. VOC - Volatile Organic Chemicals
16. WTP - Water Treatment Plant
17. The "<" Symbol : A symbol that means less than. A result of <5 means that the lowest level that could be detected was 5 and the contaminant in that sample was not detected.